



**Study on Cross section Libraries for Shielding Design
of Spent Fuel Cask and Cask Storage Facility**

Oct. 6, 2010

T. Takahashi, T. Tsukiyama, Y. Nemoto, Hitachi-GE Nuclear Energy, Ltd., Japan

S. Nemezawa, Ibaraki-Hitachi Information Service Co., Ltd., Japan

Contents

1 Introduction

1-1 Background

1-2 Purpose

I -1 Background

- **Dose limits** of regulation for casks in Japan
 - **2 mSv/h** at the surface
 - **0.1mSv/h** at the 1m point from the surface
- Typical **calculation method** for the licensing of casks
 - [1] Dose calculation
 - Calculation code : Sn transport codes (ANISN,DORT)
 - Cross-section library : **DLC23/CASK**
 - [2] Source term calculation
 - Calculation code : ORIGEN
 - Cross-section library : **BWRU**

◆ **These two** libraries are relatively old and some problems were pointed out




Fig. Spent fuel cask

- **Problems** pointed out previously
 - [1] **DLC23/CASK** (Dose calculation)
 - Calculation results **underestimate** the measurement values in some case such as the model with thick iron
 - [2] **BWRU** (Source term calculation)
 - Calculation results for low burn-up fuels **underestimate** the measurement values of neutron
 - Burn-up level of recent fuels is out of range covered by BWRU
- While **some other updated libraries** are available to use
 - [1] Dose calculation
 - **MATXSLIB** (JENDL3.3)
 - **VITAMIN-B6** (ENDFB-VI)
 - [2] Source term calculation
 - **ORLIB-J33** (JENDL3.3)
 - **GE8x8-4** (ENDFB-VI)

- **Purpose**
 - (i) Confirm the safety margins of results conducted by using currently-used library
 - (ii) Assess the applicability of the updated libraries

- **Contents** of this presentation
 - [1] Dose calculation
 - (i) Calculate neutron dose in iron
 - (ii) Calculate gamma dose in iron
 - (iii) Discuss the applicability of each libraries

 - [2] Source term calculation
 - (i) Define the calculation conditions (burn-up level)
 - (ii) Discuss the applicability of each libraries



Contents

2 Dose calculation


2-1 Neutron dose calculation in iron

2-2 Gamma dose calculation

2 -1 Neutron dose calculation in iron

- Configuration of benchmark test^[1] and calculation model

Configuration of benchmark test



Detectors and its working energy range


Detector	Working energy range
$^{32}\text{S}(n, \gamma)$	$1.6 \text{ MeV} < E$
$^{115}\text{In}(n, n')$	$0.4 \text{ MeV} < E$
$^{103}\text{Rh}(n, n')$	$40 \text{ keV} < E$
$\text{Cd}\{^{197}\text{Au}(n, \gamma)$	$0.55\text{eV}-100\text{keV}$

}

[1] J. Butler, et al., SINBAD ABSTRACT NEA-1517/34



Winfrith Iron Benchmark Experiment (ASPIS)

Calculation model



2 -1 Neutron dose calculation in iron


Attenuation of reaction rate for ^{103}Rh in iron



- ◆ DLC23/CASK and VITAMIN-B6 underestimate the measurement for iron more than 50cm thick.
- ◆ MATXSLIB shows good agreement with the measurement

2 -1 Neutron dose calculation in iron



Attenuation of reaction rate for ^{197}Au in iron



- ◆ DLC23/CASK underestimate the measurement for iron more than 50cm thick

2 -2 Gamma dose calculation

Gamma dose attenuation in iron




Library	Energy-group structure
mcplib02 (MCNP5)	- (continuous)
MATXSLIB-J33	42 groups
VITAMIN-B6	42 groups
DLC23/CASK	18 groups
MATXSLIB-J33 (Edt.)	18 groups

- ◆ Only DLC23/CASK overestimated the measurement
- ◆ MATXSLIB-J33(Edt.) is an edited library having 18 energy-group structure as contracted from MATXSLIB-J33.

2 -2 Gamma dose calculation


Libraries

- MATXSLIB-J33
- DLC23/CASK, MVITAMIN-



Libraries

- **MATXSLIB-J33 (Edt.)**
- DLC23/CASK



◆ Overestimation shown by using DLC23/CASK caused by the coarse energy-group structure

2 -2 Gamma dose calculation

- Comprehensive evaluation of applicability to shielding design

	DLC23/CASK	MATXSLIB-J33	VITAMIN-B6
Neutron	△ Underestimation	○ Good	△ Underestimation
Gamma	△ Overestimation	○ Good	○ Good
Comprehensive	△ Fair	○ Good	○ Good

- ◆ DLC23/CASK and VITAMIN-B6 **can be applied** to shielding design of general shaped casks with iron less than 50cm thick.
- ◆ MATXSLIB-J33 would be **better** library due to its better agreement with measured values.



Contents

3 Source term calculations



3-1 Background

3-2 Examination method

3-3 Result and discussion

3 -1 Background

- **Problems of BWRU** pointed out previously
 - Calculation results for low burn-up fuels **underestimate** the measurement values of neutron
 - Burn-up level of recent fuels is out of range covered by BWRU (burn-up range covered by BWRU : less than 27.5 (GWd/t))



- **Purpose**
 - Confirm the safety margins of the total amount of neutron conducted by using **BWRU** and updated libraries (**ORLIB-J33, GE8x8-4**)

3 -2 Examination method

- **Benchmark**
 - SF-98^[2] was selected as high burn-up
 - Type of reactor : BWR
 - Initial enrichment of ^{235}U : 3.91 (wt%)
 - Average void ratio : 43 (%)
 - Burn-up : 27-44 (GWd/t)
- **Examination method**
 - Total amount of neutron was regarded as the same amount of ^{244}Cm .
(The contributing rate of ^{244}Cm was more than 90%)
 - Total amount of ^{244}Cm was calculated as sum total at five points as shown in right Fig.




Fig. Sampling points of the fuel rod

[2] Science and Technology Agency of Japan,
Post Irradiation Examination for the Spent Fuel Samples

3 -3 Result and discussion

- **Calculation conditions**
 - Same condition as benchmark except void-ratio
 - Void-ratio
 - BWRU : 40% (Library constraint)
 - ORLIB-J33 : 40%, 70% (Library constraint)
- **Calculation results**
 - Relative amount of ^{244}Cm calculated as C/E

	ORIGEN2.2		
	BWRU Void ratio = 40	ORLIB-J33 (JENDL3.3)	
		Void ratio = 40	Void ratio = 70
C/E (Total of 5 point)	1.03	0.92	1.14

- ◆ BWRU : results have several percent safety margins compared to measured values
- ◆ ORLIB-J33 : Void-ratio is recommended to be set by 70% to avoid underestimation

3 -3 Result and discussion

- **Calculation conditions**
 - Same condition as benchmark except void-ratio
 - Void-ratio
GE8x8-4 : 43%, 50%, 60% (No constraint)
- **Calculation results**
 - Relative amount of ^{244}Cm calculated as C/E

	ORIGEN-ARP		
	GE8x8-4 (ENDF/B-VI)		
	Void ratio = 43	Void ratio = 50	Void ratio = 60
C/E (Total of 5 point)	0.96	1.02	1.09

◆ GE8x8-4 can be applied to shielding design when the void-ratio is set appropriately

Contents

4 Conclusion

[1] Dose calculation

DLC23/CASK and VITAMIN-B6 **can be applied** to shielding design of general shaped casks with iron less than 50cm thick.

MATXSLIB-J33 would be **better** library due to its better agreement with measured values.

[2] Source term calculation

BWRU will be able to applied to shielding design to define the neutron strength of high burn-up fuel and results have several percent safety margins.

ORLIB-J33 and GE8x8-4 also can be applied to shielding design by setting the void-ratio appropriately.

END

Study of Cross section Libraries for Shielding Design
of Spent Fuel Cask and Cask Storage Facility

Oct. 6, 2010

T. Takahashi, Hitachi-GE Nuclear Energy, Ltd., Japan